



# **Recycle Ponds Initial Inflow Design Flood Control System Plan**

**Independence Steam Electric Station  
Newark, Independence County, Arkansas**

**October 2018**

*Prepared For  
Entergy Arkansas, Inc.*



*[Handwritten Signature]* 10/24/18

---

R. Kent Nilsson, P.E.  
Senior Engineer

*[Handwritten Signature]*

---

Jason House  
Project Manager

# Table of Contents

---

Revision History.....	ii
1. Background .....	3
1.1 Documents Reviewed.....	3
1.2 Existing Conditions.....	3
2. Inflow Design Flood Control .....	6
2.1 Recycle Ponds Operation .....	7
2.2 Run-on Control.....	7
2.3 Pumping Capacity .....	8
2.4 Conclusions.....	8
3. Notifications .....	9
4. Amendment and Periodic Plan Revision .....	10
5. References.....	11
6. Certification.....	12

## List of Figures

Figure 1	Site Location Map.....	4
Figure 2	Site Detail .....	5

## List of Appendices

Appendix A Flood Information  
Appendix B Storm Water Calculations

# Revision History

---

Revision Number	Revision Date	Section Revised	Summary of Revisions

# Section 1

## Background

---

Entergy Arkansas (Entergy) operates the Independence Steam Electric Station (Plant), located at 555 Point Ferry Rd, Newark, AR 72562. This Plant operates two Water Recycle Ponds: East and West (Ponds), as part of its process water system for bottom ash transport. Pursuant to United States Environmental Protection Agency (USEPA) Disposal of Coal Combustion Residuals (CCR) From Electric Utilities Final Rule (CCR Rule) Section 40 Code of Federal Regulations (CFR) § 257.82, this Initial Inflow Design Flood Control System Plan (Plan) presents the design and construction features of the Ponds that adequately manage and maintain the inflow design flood control system.

### 1.1 Documents Reviewed


To develop this plan the following documents were reviewed by TRC:

- Entergy’s Independence Steam Electric Station Bottom Ash Work Plan. Document SD-1204.05A. Rev 2. November 10, 2008.
- Outfall Locations and Drainage Plan developed by Woodward Clyde Consultants, File No. 92T156C-A106. Rev 1. 8/23/16
- Topographic Survey performed by B&F Engineering, Inc. 10/4/18
  - Recycle Ponds Plan View. Drawing EX 1/2

### 1.2 Existing Conditions

The Plant is located near Newark, Independence County, Arkansas (Figure 1). The Plant is located at approximate latitude 35°40’39” N, longitude 91°24’42” W (front gate). The Ponds are located on the southern side of the Plant. The East and West Ponds have an approximate surface area of 7.0 acres each. The typical water level elevation in each pond is approximately 235 ft North American Vertical Datum of 1988 (NAVD88) based on field observations during July 2018. Topography surrounding the immediate vicinity of the Ponds is generally flat-lying, with existing ground surface elevations ranging from approximately 235 to 239 ft NAVD88. Natural topography in the vicinity of the ponds is relatively flat to gently sloping.

Water contained in the Ponds is part of the facility’s bottom ash transport system. There are storm water swales around the Ponds to control storm water and limit the volume of run-on. The natural ground beyond the ponds gently slopes to the southwest. A topographic survey completed by B&F Engineering, Inc. in October 2018(b) confirmed the elevations of the top of ground surface surrounding the ponds and the other surrounding areas.



**LEGEND**

 EXTENTS OF 100-YEAR FLOODPLAIN

BASE MAP FROM USGS 7.5 MINUTE TOPOGRAPHIC QUADRANGLE SERIES.




Two United Plaza  
8550 United Plaza Blvd., Suite 502  
Baton Rouge, LA  
Phone: 225.216.7483


PROJECT: **ENTERGY INDEPENDENCE STEAM ELECTRIC STATION  
RECYCLE PONDS  
NEWARK, INDEPENDENCE COUNTY, ARKANSAS**

TITLE: **INITIAL INFLOW DESIGN  
FLOOD CONTROL SYSTEM PLAN  
SITE LOCATION MAP**



DRAWN BY: A. REIS  
CHECKED BY: N. ADDISON  
APPROVED BY: J. HOUSE  
DATE: SEPTEMBER 2018  
PROJ. NO.: 302969  
FILE: 302969-001slm.mxd

**FIGURE 1**





**LEGEND**

-  APPROXIMATE PROPERTY BOUNDARY
-  EXTENTS OF 100-YEAR FLOODPLAIN



BASE MAP FROM 1 FT IMAGERY, ARKANSAS GIS OFFICE, 2017  
 FLOOD DATA ACQUIRED FROM FEMA NATIONAL FLOOD HAZARD LAYER (NFHL).



TRC - GIS

PROJECT: **ENERGY INDEPENDENCE STEAM ELECTRIC STATION  
 RECYCLE PONDS  
 NEWARK, INDEPENDENCE COUNTY, ARKANSAS**

TITLE: **INITIAL INFLOW DESIGN  
 FLOOD CONTROL SYSTEM PLAN  
 SITE DETAIL**

DRAWN BY: A. REIS  
 CHECKED BY: N. ADDISON  
 APPROVED BY: J. HOUSE  
 DATE: SEPTEMBER 2018  
 PROJ. NO.: 302969  
 FILE: 302969-002.mxd

**FIGURE 2**

## Section 2

# Inflow Design Flood Control

---

40 C.F.R. § 257.82 specifies requirements for hydrologic and hydraulic capacity of CCR units. The purpose of this report is to demonstrate the hydrologic and hydraulic capacity of the Ponds meet the requirement of the CCR Rule. Per ERM's Report, the Ponds are incised, therefore, a hazard potential classification is not needed per 40 CFR § 57.73(a). Based on the incised potential classification, the CCR surface impoundment unit must adequately manage flow into the unit during and following the peak discharge of the 25-year flood (40 CFR 257.82(a)(3)(iv)).

The Ponds were designed and utilized as part of the Plant's bottom ash transport water system. The design meets the requirements of 40 CFR § 257.82(a)(1), (2) and (3), which states:

*(1) The inflow design flood control system must adequately manage flow into the CCR unit during and following the peak discharge of the inflow design flood specified in paragraph (a)(3) of this section.*

*(2) The inflow design flood control system must adequately manage flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood specified in paragraph (a)(3) of this section.*

*(3) The inflow design flood is:*

*(i) For a high hazard potential CCR surface impoundment, as determined under § 257.73(a)(2) or §257.74(a)(2), the probable maximum flood;*

*(ii) For a significant hazard potential CCR surface impoundment, as determined under 257.73(a)(2) or §257.74(a)(2), the 1000-year flood;*

*(iii) For a low hazard potential CCR surface impoundment, as determined under 257.73(a)(2) or §257.74(a)(2), the 100-year flood;*

*(iv) For an incised CCR surface impoundment, the 25-year flood.*

The Flood Insurance Rate Map (Federal Emergency Management Agency, 2010) indicates that the Ponds are located in an area mapped in Zone A of the special flood hazard areas subject to inundation by the 1 percent annual chance flood, refer to Appendix A. Figures 1 and 2 show the extents of the 100-year flood plain. Zone A is an area on the Flood Insurance Rate Map where the base flood elevation has not been determined. Therefore, to estimate the elevation of the 25-year flood for this Plan, an interpolation was performed using the nearest upstream and

downstream locations where the flood elevations had been determined in the Flood Insurance Study (Federal Emergency Management Agency, 2012). This estimate resulted in a 25-year flood elevation of approximately elevation 235 in the vicinity of the Ponds. Based on this result and the survey information, the Ponds are assumed to be above the elevation of the 25-year flood; therefore, a dedicated system to control flood waters is not required. The Ponds have been designed with inflow features presented in the sections below to mitigate and control stormwater inflows during a 25-year storm event.

In addition to the flood control requirements above, 40 C.F.R § 257.82(b) addresses discharges:

*Discharge from the CCR unit must be handled in accordance with the surface water requirements under §257.3-3.*

The Ponds were designed and utilized as part of the Plant's bottom ash transport water system and comply with the requirements of 40 CFR § 257.82(b). Water discharges from the Plant are permitted through the Arkansas Department of Environmental Quality (ADEQ) for the National Pollutant Discharge Elimination System.

## 2.1 Recycle Ponds Operation

The Ponds are utilized as part of the Plant's bottom ash transport water system. Site infrastructure enables the Ponds to be operated either singularly, in parallel, or in series. The Ponds can be drained via pumps in a pump house located between the ponds with a 30-inch intake pipe from each pond. The Ponds were designed to operate with 2 feet of freeboard, height difference from the top of the surrounding ground surface to the design water level. In the event both Ponds reach capacity, overflow from the Ponds flows through a culvert and ditch located in the north west corner of Pond A. The ditch discharges to the surge pond.

The following control measures are implemented during operation to control the water levels in the Ponds:

- Operate pumps as needed to control the pond water levels.
- Regularly check and maintain grades surrounding the ponds to minimize the area contributing to storm water run-on.

## 2.2 Run-on Control

As designed, the Ponds meet the requirement to control the storm water run-on from a 25-year, 24-hour storm event based upon the Precipitation Frequency Estimates from the National Oceanic and Atmospheric Administration. As designed, the Ponds meet the requirement to operate with at least two feet of freeboard. The storm water run-on volume calculated for the



design storm was compared to the storage capacity above the Ponds design operating elevation. The evaluation determined that there is sufficient capacity in the Ponds when operating with two feet of freeboard to accept run-on volume from a 25-year, 24-hour storm event, refer to Appendix B.

## 2.3 Pumping Capacity

The pump station is equipped with six (three per unit) Gould single stage centrifugal pumps with a rated pumping capacity of 2750 gallons per minute (gpm) at 307 feet of head in the LP Ash Water Pump house. A calculation was performed to determine length of time required to remove the anticipated run-on due to a 25-year, 24-hour storm event, refer to Appendix B. The calculation was performed assuming only two operational pumps and resulted in a required time of 10.3 hours or approximately .5 days to remove the anticipated storm water run-on collected in both Ponds. This calculation shows that pumping rates are sufficient in controlling water levels in the Ponds.

## 2.4 Conclusions

The Ponds meet the requirements of 40 CFR § 257.82 of adequately controlling the inflows and outflows of peak discharge at the Plant for the following reasons:

- The Ponds are located above the 25-year flood elevation.
- The Ponds were adequately designed to withstand a 25-year, 24-hour storm event.
- The pumping rates are sufficient to control the water levels in the Ponds.

## Section 3 Notifications

---

In accordance with 40 CFR § 257.105(g), Entergy will post to the Plant's Facility Operating Record (FOR) the Initial Inflow Design Flood Control System Plan. The Director of the ADEQ will be notified when documents are available as per 40 CFR § 257.106(g) and notices and documents will be placed on Entergy's CCR website consistent with 40 CFR § 257.107(g).

## Section 4

# Amendment and Periodic Plan Revision

---

In accordance with 40 CFR § 257.82(c)(2), Entergy may amend this Initial Inflow Design Flood Control System Plan at any time. Specifically, Entergy will amend the inflow design flood control system plan whenever there is a change in the operation of the CCR unit that would substantially affect the written plan in effect. A periodic inflow design flood control system plan must also be prepared every 5 years from the completion date of this plan. Recordkeeping, Notification and Posting requirements of 40 CFR § 257.105, 257.106 and 257.107 will be followed.

## Section 5 References

---

B&F Engineering, Inc. 2018b. Topographic Survey: Independence Recycle Ponds Entergy Arkansas. October 4, 2018. Drawing.

Federal Emergency Management Agency. 2012. Flood Insurance Study: Independence County, Arkansas and Incorporated Areas. Flood Insurance Study Number 05063CV000B. Revised March 15, 2012. United States Department of Homeland Security. Washington, D. C.

Federal Emergency Management Agency. 2010. Flood Insurance Rate Map: Independence County, Arkansas and Incorporated Areas. Panel 400 of 550. Map Number 05063C0400D. Effective Date March 17, 2010. National Flood Insurance Program. Washington, D. C.

ERM. 2018b. Summary of Site Visit and Review of CCR Structural Integrity Criteria Requirements for Entergy Independence Steam Electric Station (ISES) Recycle Pond. October 2018.

# Section 6 Certification

I, the undersigned Arkansas Professional Engineer, hereby certify that I am familiar with the technical requirements of 40 CFR § 257.82. I also certify that it is my professional opinion that, to the best of my knowledge, information, and belief, that the information in this inflow design flood control system plan is in accordance with current good and accepted engineering practice(s) and standard(s) and meets the technical requirements of 40 CFR § 257.82(c).

For the purpose of this document, "certify" and "certification" shall be interpreted and construed to be a "statement of professional opinion." The certification is understood and intended to be an expression of my professional opinion as an Arkansas Licensed Professional Engineer, based upon knowledge, information, and belief. The statement(s) of professional opinion are not and shall not be interpreted or construed to be a guarantee or a warranty of the analysis herein.



R. Kent Nilsson

9136

Printed Name of Professional Engineer

State of Arkansas License Number

10/24/18

Signature of Professional Engineer

Date



# Appendix A

## Flood Information

---

- Flood Insurance Rate Map
- 25-Year Flood Elevation Estimate

**NOTES TO USERS**

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

To obtain more detailed information in areas where **Base Flood Elevations (BFEs)** and/or **floodways** have been determined, users are encouraged to consult the **Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations** tables contained within the **Flood Insurance Study (FIS)** report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent rounded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or floodplain management.

**Coastal Base Flood Elevations** shown on this map apply only landward of 0.7 North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the **Summary of Stillwater Elevations** table in the **Flood Insurance Study** report for this jurisdiction. Elevations shown in the **Summary of Stillwater Elevations** table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the **Flood Insurance Study** report for this jurisdiction.

Certain areas not in Special Flood Hazard Areas may be protected by **flood control structures**. Refer to Section 2.4 "Flood Protection Measures" of the **Flood Insurance Study** report for information on flood control structures for this jurisdiction.

The projection used in the preparation of this map was the **Arkansas State Plane north zone (FIPSZONE 0301)**. The **horizontal datum** was **NAD83, GRS1980 spheroid**. Differences in datum, spheroid, projection or State Plane zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of the FIRM.

Flood elevations on this map are referenced to the **North American Vertical Datum of 1988**. These flood elevations must be compared to structure and ground elevations referenced to the same **vertical datum**. For information regarding conversion between the **North American Vertical Datum of 1929** and the **North American Vertical Datum of 1988**, visit the **National Geodetic Survey** website at <http://www.ngs.noaa.gov/> or contact the **National Geodetic Survey** at the following address:

NGS Information Services  
NOAA, NINGS12  
National Geodetic Survey  
SSHC-3, #5002  
1315 East-West Highway  
Silver Spring, MD 20910-3282

To obtain current elevation, description, and/or location information for **bench marks** shown on this map, please contact the **Information Services Branch** of the **National Geodetic Survey** at (301) 713-3242, or visit its website at <http://www.ngs.noaa.gov/>.

**Base map** information shown on the FIRM was provided in digital format by the **Arkansas Geographic Information Office**, 2007.


This map reflects more detailed and up-to-date **stream channel configurations** than those shown on the previous FIRM for this jurisdiction. The **floodplains** and **floodways** that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the **Flood Profiles and Floodway Data** tables in the **Flood Insurance Study** report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.

**Corporate limits** shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels; community map repository addresses; and a **Listing of Communities** table containing **National Flood Insurance Program** dates for each community as well as a listing of the panels on which each community is located.


Contact the **FEMA Map Service Center** at 1-800-358-9616 for information on available products associated with this FIRM. Available products may include previously issued **Letters of Map Change**, a **Flood Insurance Study** report, and/or digital versions of this map. The **FEMA Map Service Center** may also be reached by Fax at 1-800-358-9620 and its website at <http://www.msc.fema.gov/>.

If you have **questions about this map** or questions concerning the **National Flood Insurance Program** in general, please call 1-877-FEMA-MAP(1-877-336-2627) or visit the **FEMA** website at <http://www.fema.gov/>.



**LEGEND**

- SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD**
- ZONE A** No Base Flood Elevations determined.
- ZONE AE** Base Flood Elevations determined.
- ZONE AH** Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations determined.
- ZONE AO** Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determined.
- ZONE AR** Special Flood Hazard Area formerly protected from the 1% annual chance flood by a flood control system that was subsequently deteriorated. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.
- ZONE A99** Area to be protected from 1% annual chance flood by a Federal flood protection system under construction; no Base Flood Elevations determined.
- ZONE V** Coastal flood zone with velocity hazard (wave action); no Base Flood Elevations determined.
- ZONE VE** Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.
- FLOODWAY AREAS IN ZONE AE**
- OTHER FLOOD AREAS**
- ZONE X** Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.
- OTHER AREAS**
- ZONE X** Areas determined to be outside the 0.2% annual chance floodplain.
- ZONE D** Areas in which flood hazards are undetermined, but possible.
- COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS**
- OTHERWISE PROTECTED AREAS (OPAs)**
- CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.
- Floodplain boundary
- Floodway boundary
- Zone D boundary
- CBRS and OPA boundary
- Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities.
- Base Flood Elevation line and value; elevation in feet\*  
(EL 987)
- Base Flood Elevation value where uniform within zone; elevation in feet\*  
(EL 987)
- \* Referenced to the North American Vertical Datum of 1988 (NAVD 88)
- Cross section line
- Transect line
- Geographic coordinates referenced to the North American Datum of 1983 (NAD 83)
- 1000-meter Universal Transverse Mercator grid ticks, zone 15
- 5000-foot grid ticks; Arkansas State Plane coordinate system, north zone (FIPSZONE 0301), Lambert Conformal Conic
- Bench mark (see explanation in Notes to Users section of this FIRM panel)
- River Mile
- MAP REPOSITORIES
- Refer to Map Repositories list on Map Index
- EFFECTIVE DATE OF COUNTY-WIDE FLOOD INSURANCE RATE MAP  
March 17, 2010
- EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL



**NATIONAL FLOOD INSURANCE PROGRAM**

**PANEL 0400D**

**FIRM FLOOD INSURANCE RATE MAP**

**INDEPENDENCE COUNTY, ARKANSAS AND INCORPORATED AREAS**

**PANEL 400 OF 550**  
(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

**CONTAINS:**


COMMUNITY	NUMBER	PANEL	SUFFIX
INDEPENDENCE COUNTY	050090	0400	D
MAGNESS, TOWN OF	050482	0400	D
NEWARK, CITY OF	050092	0400	D
OIL TROUGH TOWN OF	050093	0400	D
SULPHUR ROCK TOWN OF	050090	0400	D

Notice to User: The **Map Number** shown below should be used when placing map orders. The **Community Number** shown above should be used on insurance applications for the subject community.

**MAP NUMBER 05063C0400D**

**EFFECTIVE DATE MARCH 17, 2010**

Federal Emergency Management Agency






# FLOOD INSURANCE STUDY



## INDEPENDENCE COUNTY, ARKANSAS AND INCORPORATED AREAS

Community Name	Community Number
BATESVILLE, CITY OF	050091
CAVE CITY, CITY OF	050313
CUSHMAN, TOWN OF	050403
MAGNESS, TOWN OF	050482
MOOREFIELD, TOWN OF	050483
NEWARK, CITY OF	050092
OIL TROUGH, TOWN OF	050093
PLEASANT PLAINS, TOWN OF	050484
SULPHUR ROCK, TOWN OF	050290
INDEPENDENCE COUNTY (UNINCORPORATED AREAS)	050090




REVISED: March 15, 2012




Federal Emergency Management Agency

FLOOD INSURANCE STUDY NUMBER  
05063CV000B








FLOOD PROFILES

WHITE RIVER (UPPER REACH)

FEDERAL EMERGENCY MANAGEMENT AGENCY  
 INDEPENDENCE COUNTY, AR  
 AND INCORPORATED AREAS



FLOOD PROFILES

WHITE RIVER (UPPER REACH)

FEDERAL EMERGENCY MANAGEMENT AGENCY  
 INDEPENDENCE COUNTY, AR  
 AND INCORPORATED AREAS

# Appendix B

## Storm Water Calculations

---

- Storm Water Run-On Estimate
- Pumping Time Estimate



PROJECT / LOCATION: Entergy Independence Steam Electric Station - Newark, AR		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of West and East Recycle Ponds		302969.0000
PREPARED BY: A. Sampson	DATE: 9/5/2018	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 9/9/2018	REVISION <input type="checkbox"/>

Purpose: Determine if 2 feet of freeboard is capable of containing the runoff volume from the 25-year, 24-hour storm event

Methodology:

1.) Determine the storage capacity of 2 feet Freeboard

- Storage Capacity of West Pond between EL. 235' and EL. 237'

$S_{FB}$  Storage Volume at Freeboard (from attached HydroCAD model)  
 $S_{IFB}$  Total Freeboard Storage Volume

$$S_{FB} = 587,616 \text{ ft}^3$$

- Storage Capacity of East Pond between EL. 235' and EL. 237'

Freeboard Storage Capacity (Volumes are from attached HydroCAD model)

$$S_{FB} = 533,824 \text{ ft}^3$$

-Total Freeboard Storage Capacity of West Pond and East Pond Combined

$$S_{IFB} = 1,121,440 \text{ ft}^3$$



PROJECT / LOCATION: Entergy Independence Steam Electric Station - Newark, AR		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of West and East Recycle Ponds		302969.0000
PREPARED BY: A. Sampson	DATE: 9/5/2018	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 9/9/2018	REVISION <input type="checkbox"/>

2.) Determine the storm water runoff volume that flows into the basins from the 25-year, 24-hour storm event

$$\begin{aligned}
 V_R &= \text{Volume of Runoff} \\
 \text{Area} &= 19.8 \text{ ac} \\
 \text{Rainfall} \\
 \text{Rate} &= 6.35 \text{ in/ac} \quad \text{Design storm data from NOAA, refer to attached sheets}
 \end{aligned}$$

$$\begin{aligned}
 V_R &= \text{Area} * \text{Rainfall Rate} \\
 V_R &= 456,400 \text{ ft}^3
 \end{aligned}$$

3.) Compare Freeboard Capacity to Volume of Runoff to determine if the Freeboard is capable of containing 100-year, 24-hour storm event.

- If  $S_{IFB} > V_R$ , then the Freeboard design is OK

$$\begin{aligned}
 S_{IFB} &= 1,121,440 \text{ ft}^3 \\
 V_R &= 456,400 \text{ ft}^3
 \end{aligned}$$

$$S_{IFB} > V_R$$

Conclusion: Because the  $S_{IFB} > V_R$ , the 2 feet of freeboard is capable of containing the runoff volume of the 25-year, 24-hour storm event





PROJECT / LOCATION: Entergy Independence Steam Electric Station - Newark, AR		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of West and East Recycle Ponds		302969.0000
PREPARED BY: A. Sampson	DATE: 9/5/2018	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 9/9/2018	REVISION <input type="checkbox"/>

## ATTACHMENTS

	BY	DATE
Design	RLS	7/18
Drawn	RLS	7/18
Checked		
Survey	TAW	7/18
Plat Blk. #		2177
Rev #		

BM PROJ: 7-4183-0201  
FILE NAME: 001-FINAL  
ISSUE DATE: 10/01/18

SCALE  
1" = 80'

1  
1

REV # | REV DATE | BY | REVISIONS

LEGEND


--- 235 ---	MAJOR CONTOUR INSET
--- 236 ---	MINOR CONTOUR

- GENERAL NOTES:
- THIS SURVEY REPRESENTS A TOPOGRAPHIC SURVEY OF THE INDEPENDENCE RECYCLE PONDS.
  - COORDINATES ARE NAD83(2011) ARKANSAS NORTH ZONE (3011 US SURVEY FEET) PROVIDED BY INTERUM. ELEVATIONS ARE BASED ON FOUND MONUMENT SC-1 (LOCAL CONTROL).
  - FIELD SURVEY WAS PERFORMED ON JULY 8TH, 10TH, 11TH, AND AUGUST 9TH, 2018.




CONTROL TABLE


PT #	NORTHING	EASTING	ELEVATION	DESCRIPTION
1	48784.1070	1488477.3640	238.07	REBAR/ALUM CAP
2	487438.7750	1488509.5530	238.26	MAGNETIC NAIL
17	487562.2990	1492990.0460	238.92	BRASS DISK IN CONC. SC-1





Drainage Area  
Flowing to  
Ponds from  
Storm Water



West Pond



East Pond



# Independence Recycle Ponds

Prepared by TRC

HydroCAD® 10.00-20 s/n 01402 © 2017 HydroCAD Software Solutions LLC

Printed 9/5/2018

Page 2

## Area Listing (all nodes)

Area (acres)	CN	Description (subcatchment-numbers)
<b>0.000</b>	<b>0</b>	<b>TOTAL AREA</b>

# Independence Recycle Ponds

Prepared by TRC

HydroCAD® 10.00-20 s/n 01402 © 2017 HydroCAD Software Solutions LLC

Printed 9/5/2018

Page 3

## Soil Listing (all nodes)

Area (acres)	Soil Group	Subcatchment Numbers
0.000	HSG A	
0.000	HSG B	
0.000	HSG C	
0.000	HSG D	
0.000	Other	
<b>0.000</b>		<b>TOTAL AREA</b>

# Independence Recycle Ponds

Prepared by TRC

HydroCAD® 10.00-20 s/n 01402 © 2017 HydroCAD Software Solutions LLC

Printed 9/5/2018

Page 4

## Ground Covers (all nodes)

HSG-A (acres)	HSG-B (acres)	HSG-C (acres)	HSG-D (acres)	Other (acres)	Total (acres)	Ground Cover	Subcatchment Numbers
0.000	0.000	0.000	0.000	0.000	0.000	<b>TOTAL AREA</b>	

## Independence Recycle Ponds

Prepared by TRC

HydroCAD® 10.00-20 s/n 01402 © 2017 HydroCAD Software Solutions LLC

*Rainfall not specified*

Printed 9/5/2018

Page 5

Time span=5.00-20.00 hrs, dt=0.05 hrs, 301 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

**Pond E: East Pond**

Peak Elev=0.00' Storage=0 cf

**Pond W: West Pond**

Peak Elev=0.00' Storage=0 cf

# Independence Recycle Ponds

Prepared by TRC

HydroCAD® 10.00-20 s/n 01402 © 2017 HydroCAD Software Solutions LLC

*Rainfall not specified*

Printed 9/5/2018

Page 6

## Summary for Pond E: East Pond

[43] Hint: Has no inflow (Outflow=Zero)

Volume	Invert	Avail.Storage	Storage Description
#1	235.00'	834,622 cf	<b>Custom Stage Data (Prismatic)</b> Listed below (Recalc)
Elevation (feet)	Surf.Area (sq-ft)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)
235.00	253,568	0	0
236.00	264,923	259,246	259,246
237.00	284,234	274,579	533,824
238.00	317,361	300,798	834,622



# Independence Recycle Ponds

Prepared by TRC

HydroCAD® 10.00-20 s/n 01402 © 2017 HydroCAD Software Solutions LLC

*Rainfall not specified*

Printed 9/5/2018

Page 7

## Summary for Pond W: West Pond

[43] Hint: Has no inflow (Outflow=Zero)

Volume	Invert	Avail.Storage	Storage Description
#1	235.00'	907,352 cf	<b>Custom Stage Data (Prismatic)</b> Listed below (Recalc)
Elevation (feet)	Surf.Area (sq-ft)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)
235.00	286,201	0	0
236.00	293,688	289,945	289,945
237.00	301,655	297,672	587,616
238.00	337,817	319,736	907,352



**NOAA Atlas 14, Volume 9, Version 2**  
**Location name: Newark, Arkansas, USA\***  
**Latitude: 35.6717°, Longitude: -91.4017°**  
**Elevation: 238.17 ft\*\***  
 \* source: ESRI Maps  
 \*\* source: USGS



**POINT PRECIPITATION FREQUENCY ESTIMATES**

Sanja Perica, Deborah Martin, Sandra Pavlovic, Ishani Roy, Michael St. Laurent, Carl Trypaluk, Dale Unruh, Michael Yekta, Geoffrey Bonnin

NOAA, National Weather Service, Silver Spring, Maryland

[PF tabular](#) | [PF graphical](#) | [Maps & aeriels](#)

**PF tabular**

<b>PDS-based point precipitation frequency estimates with 90% confidence intervals (in inches)<sup>1</sup></b>										
Duration	Average recurrence interval (years)									
	1	2	5	10	25	50	100	200	500	1000
5-min	0.415 (0.355-0.489)	0.472 (0.403-0.556)	0.564 (0.481-0.665)	0.640 (0.544-0.756)	0.744 (0.620-0.889)	0.823 (0.677-0.990)	0.902 (0.728-1.10)	0.981 (0.773-1.21)	1.09 (0.836-1.35)	1.16 (0.884-1.46)
10-min	0.608 (0.520-0.716)	0.691 (0.591-0.814)	0.826 (0.705-0.974)	0.937 (0.797-1.11)	1.09 (0.908-1.30)	1.21 (0.992-1.45)	1.32 (1.07-1.61)	1.44 (1.13-1.77)	1.59 (1.22-1.98)	1.70 (1.29-2.14)
15-min	0.741 (0.634-0.873)	0.842 (0.720-0.993)	1.01 (0.860-1.19)	1.14 (0.972-1.35)	1.33 (1.11-1.59)	1.47 (1.21-1.77)	1.61 (1.30-1.96)	1.75 (1.38-2.15)	1.94 (1.49-2.41)	2.08 (1.58-2.61)
30-min	1.08 (0.922-1.27)	1.23 (1.05-1.44)	1.47 (1.25-1.73)	1.66 (1.41-1.97)	1.93 (1.61-2.31)	2.14 (1.76-2.57)	2.35 (1.89-2.89)	2.59 (2.07-3.11)	2.86 (2.28-3.44)	3.08 (2.44-3.72)
60-min	1.42 (1.21-1.67)	1.60 (1.37-1.89)	1.90 (1.62-2.24)	2.16 (1.83-2.55)	2.51 (2.10-3.01)	2.79 (2.30-3.36)	3.06 (2.48-3.73)	3.35 (2.65-4.13)	3.73 (2.88-4.66)	4.03 (3.06-5.06)
2-hr	1.76 (1.52-2.05)	1.98 (1.71-2.31)	2.34 (2.02-2.73)	2.65 (2.27-3.10)	3.09 (2.61-3.67)	3.43 (2.86-4.10)	3.78 (3.09-4.58)	4.15 (3.31-5.08)	4.64 (3.62-5.76)	5.03 (3.86-6.27)
3-hr	1.98 (1.72-2.29)	2.22 (1.92-2.57)	2.61 (2.26-3.04)	2.96 (2.55-3.44)	3.45 (2.93-4.09)	3.84 (3.22-4.58)	4.25 (3.49-5.12)	4.67 (3.75-5.70)	5.25 (4.12-6.49)	5.71 (4.41-7.09)
6-hr	2.41 (2.11-2.76)	2.70 (2.36-3.10)	3.19 (2.78-3.66)	3.61 (3.14-4.16)	4.22 (3.62-4.96)	4.71 (3.99-5.56)	5.21 (4.33-6.23)	5.75 (4.66-6.96)	6.48 (5.14-7.95)	7.05 (5.50-8.70)
12-hr	2.92 (2.58-3.32)	3.30 (2.91-3.75)	3.93 (3.46-4.47)	4.46 (3.92-5.09)	5.22 (4.52-6.07)	5.83 (4.97-6.81)	6.44 (5.40-7.63)	7.08 (5.80-8.50)	7.96 (6.37-9.69)	8.63 (6.80-10.6)
24-hr	3.49 (3.11-3.92)	3.97 (3.54-4.46)	4.76 (4.24-5.36)	5.42 (4.81-6.12)	6.35 (5.54-7.29)	7.07 (6.08-8.17)	7.79 (6.59-9.13)	8.54 (7.05-10.1)	9.53 (7.70-11.5)	10.3 (8.19-12.5)
2-day	4.09 (3.69-4.55)	4.67 (4.20-5.19)	5.61 (5.04-6.24)	6.38 (5.72-7.13)	7.45 (6.56-8.46)	8.28 (7.19-9.47)	9.10 (7.76-10.6)	9.94 (8.28-11.7)	11.0 (9.00-13.2)	11.9 (9.55-14.3)
3-day	4.49 (4.07-4.96)	5.11 (4.62-5.64)	6.11 (5.52-6.76)	6.94 (6.25-7.70)	8.08 (7.15-9.12)	8.96 (7.83-10.2)	9.85 (8.45-11.4)	10.7 (9.01-12.6)	11.9 (9.78-14.2)	12.8 (10.4-15.4)
4-day	4.82 (4.38-5.30)	5.45 (4.96-6.00)	6.50 (5.90-7.16)	7.37 (6.66-8.14)	8.57 (7.61-9.63)	9.49 (8.33-10.8)	10.4 (8.98-12.0)	11.4 (9.58-13.3)	12.6 (10.4-15.0)	13.6 (11.0-16.3)
7-day	5.61 (5.14-6.12)	6.30 (5.78-6.87)	7.45 (6.81-8.14)	8.41 (7.67-9.21)	9.74 (8.74-10.9)	10.8 (9.55-12.1)	11.8 (10.3-13.5)	12.9 (11.0-15.0)	14.4 (12.0-17.0)	15.5 (12.7-18.5)
10-day	6.32 (5.83-6.85)	7.06 (6.50-7.66)	8.28 (7.61-9.00)	9.31 (8.53-10.1)	10.7 (9.69-11.9)	11.9 (10.6-13.3)	13.0 (11.4-14.8)	14.2 (12.1-16.4)	15.8 (13.2-18.6)	17.0 (14.0-20.2)
20-day	8.43 (7.85-9.04)	9.30 (8.65-9.98)	10.7 (9.97-11.5)	11.9 (11.1-12.9)	13.6 (12.4-15.0)	14.9 (13.4-16.5)	16.2 (14.4-18.3)	17.6 (15.2-20.2)	19.4 (16.4-22.7)	20.8 (17.3-24.5)
30-day	10.2 (9.57-10.9)	11.2 (10.5-12.0)	12.9 (12.1-13.8)	14.3 (13.3-15.3)	16.2 (14.8-17.7)	17.6 (16.0-19.4)	19.1 (17.0-21.4)	20.6 (17.9-23.4)	22.5 (19.1-26.1)	23.9 (20.1-28.1)
45-day	12.5 (11.8-13.2)	13.8 (13.0-14.6)	15.8 (14.9-16.8)	17.5 (16.4-18.6)	19.7 (18.1-21.3)	21.4 (19.4-23.3)	23.0 (20.5-25.5)	24.5 (21.4-27.8)	26.6 (22.7-30.7)	28.0 (23.7-32.8)
60-day	14.5 (13.7-15.2)	16.0 (15.1-16.9)	18.4 (17.4-19.4)	20.3 (19.1-21.5)	22.9 (21.1-24.5)	24.7 (22.5-26.8)	26.5 (23.7-29.2)	28.1 (24.6-31.7)	30.2 (25.9-34.7)	31.7 (26.9-37.0)





25-year, 24-hour storm event

<sup>1</sup> Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS). Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values. Please refer to NOAA Atlas 14 document for more information.

[Back to Top](#)

# PF graphical

PDS-based depth-duration-frequency (DDF) curves  
Latitude: 35.6717°, Longitude: -91.4017°




[Back to Top](#)


## Maps & aerials

Small scale terrain







Large scale terrain



Large scale map



Large scale aerial



[Back to Top](#)

---

[US Department of Commerce](#)  
[National Oceanic and Atmospheric Administration](#)  
[National Weather Service](#)  
[National Water Center](#)  
1325 East West Highway  
Silver Spring, MD 20910  
Questions?: [HDSC.Questions@noaa.gov](mailto:HDSC.Questions@noaa.gov)

[Disclaimer](#)



PROJECT / LOCATION: Entergy Independence Steam Electric Station - Newark, AR		PROJECT / PROPOSAL NO.
SUBJECT: Estimated Pump Down Time		302969.0000
PREPARED BY: J. Bell	DATE: 8/27/2018	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 9/9/2018	REVISION <input type="checkbox"/>

Purpose: Determine the amount of time needed for the pump to remove the storm water collected during the 25-year, 24-hour storm event to design operation elevation (EL. 235)

Methodology:

- 1.) Use the volume of runoff ( $V_R$ ) from the Freeboard Volume Calculation (Refer to attached calculation sheet)

$$V_R = 456,400 \text{ ft}^3$$

- 2.) Use pump capacity rating to determine amount of time to lower the water level in both basins to EL. 235

-Assume one pump is operational for each pond

$$\text{Pump Rate} = 2,750 \text{ gallons per minute (gpm)}$$

$$V_R = 3,414,109 \text{ gallons}$$

$$\text{Time} = \frac{V_R}{(\text{Pump Rate}) * 2}$$

$$\begin{aligned} \text{Time} &= 621 \text{ min} \\ &= 10.3 \text{ hr} \\ &= 0.4 \text{ days} \end{aligned}$$

Conclusion: It will take approximately 10 hours to pump out the storm water to reestablish freeboard after the 25-year, 24-hour storm event.