

# ARKANSAS PUBLIC SERVICE COMMISSION

Original Sheet No. P12.1 Schedule Sheet 1 of 1

Replacing: Sheet No.

Entergy Arkansas, LLC  
Name of Company

Kind of Service: Electric Class of Service: Not Applicable

Docket No.: 18-073-TF  
Order No.: 2  
Effective: 2/1/19

## Part IV. Policy Schedule No. 12

**Title: Meter Testing Program (MTP)**

PSC File Mark Only

### 12.0. METER TESTING PROGRAM

Rule 7.03(g)(2) of the Arkansas Public Service Commission ("Commission") Rules of Practice and Procedure requires that each electric utility file its test method for in-service meters. Rule 7.08.C of the Commission's Special Rules - Electric (SR-E) provides that a utility shall state in its tariffs on file with the Commission which sampling method is used by the utility for testing new meters and which sampling method is used for testing in-service meters.

#### 12.1. TEST PROGRAM FOR NEW METERS

To ensure that new meters conform to the accuracy requirements of Rule 7.05.B of the Commission's Special Rules - Electric, before installation by the utility, all new meters will be inspected and tested in a meter shop or laboratory under the sampling method indicated below:

- (1) 100% of all new combination kW/kWh and kVA/kWh meters will be tested.
- (2) New kWh only meters will be tested on a sampling basis conforming to ANSI C12.1-1982, § 8.1.5.

#### 12.2. IN-SERVICE METER TESTING PROGRAM

In accordance with 7.08.B of the Commission's Special Rules - Electric, all in-service meters will be tested by the utility under the program indicated below. All meters will be tested under the same program:

- (1) Periodic interval ANSI C12.1-1982, § 8.1.8.4 and § 8.2.3.1, for combination kW/kWh, kVA/kWh and Three Phase kWh only meters.
- (2) Variable interval ANSI C12.1-1982, § 8.1.8.5.
- (3) Statistical sampling ANSI C12.1-1982, § 8.1.8.6, for Single Phase kWh only meters.